



Certificate of Compliance

Certificate: 1863602

Master Contract: 237481

Project: 2293925

Date Issued: 2010/04/12

Issued to: INOR Process AB

Slipstengatan 6

Malmö, 223 76

Sweden

Attention: Gert Paulsson

The products listed below are eligible to bear the CSA Mark shown



Edward Foo, C.E.T.

Issued by: Edward Foo, C.E.T.

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

Class I, Groups A, B, C & D:

- 4-20 mA Temperature Transmitter, Model IPAQ-HX, Intrinsically Safe with Entity Parameters $V_{max} = 30$ V, $I_{max} = 100$ mA, $P_{max} = 900$ mW, $C_i = 0$ uF, $L_i = 2.5$ mH (Terminals 5 & 6) and $V_{oc} = 30$ V, $I_{sc} = 25$ mA, $C_a = 0.12$ uF, $L_a = 56.8$ mH (Terminals 1, 2, 3 & 4) per Installation Dwg. 3-7851. Temperature Code T4 at $T_a = 80$ °C.

- Temperature Transmitter, Models APAQ-HRFX and APAQ-HCFX, Intrinsically Safe with Entity Parameters $V_{max} = 30$ V, $I_{max} = 100$ mA, $P_{max} = 700$ mW, $C_i = 0$ uF, $L_i = 0$ mH (Terminals 4 & 5) and $V_{oc} = 30$ V, $I_{sc} = 95.8$ mA, $C_a = 0.12$ uF, $L_a = 4$ mH (Terminals PL1, PL2 & PL3) per Installation Dwg. 3-7892. Temperature Code T4 at $T_a = 80$ °C.

Class I, Groups A, B, C & D; Class II, Groups E, F & G; Class III:

- 4-20 mA Temperature Transmitter, Model IPAQ-LX, associated apparatus with Intrinsically Safe output with Entity Parameters $V_{max} = 30$ V, $I_{max} = 100$ mA, $P_{max} = 900$ mW, $C_i = n/a$, $L_i = n/a$ (Terminals 5 & 6) and $V_{oc} = 30$ V, $I_{sc} = 25$ mA, $C_a = 0.12$ uF, $L_a = 56.8$ mH (Terminals 1, 2, 3 & 4) per Installation Dwg. 3-7852.

Note: Transmitter is installed in safe area.



Certificate: 1863602

Master Contract: 237481

Project: 2293925

Date Issued: 2010/04/12

Class I, Groups A, B, C & D; Class II, Group G; Class III:

• Temperature Sensor, Model MESO-HX, Intrinsically Safe with Entity Parameters $V_{max} = 30$ V, $I_{max} = 100$ mA, $P_{max} = 900$ mW, $C_i = 0$ uF, $L_i = 0$ mH (Terminals PL5 & PL6) and $V_{oc} = 30$ V, $I_{sc} = 25$ mA, $C_a = 0.12$ uF, $L_a = 56.8$ mH (Terminals PL1, PL2, PL3 & PL4) per Installation Dwg. 3-7967. Temperature Code T4 at $T_a = 80$ °C.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std. C22.2 No. 25-1966 (R2004) - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std. C22.2 No. 142-M1987 (R2004) - Process Control Equipment

CAN/CSA-C22.2 No. 157-92 (R2006) - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations