



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **KIWA 17ATEX0055X** Issue: **3**

4 Equipment: **Temperature Transmitter, Model IPAQ R530X**

5 Applicant: **INOR Process AB**

6 Address: **Travbanegatan 10  
213 77 Malmö  
Sweden**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0: 2018 EN 60079-11: 2012

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:



II 1G

Ex ia IIC T6 ... T4 Ga

Signed:

M Halliwell

Title: Director of Operations



Project Number 80213753

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

KIWA 17ATEX0055X  
Issue 3

#### 13 DESCRIPTION OF EQUIPMENT

Rail mounted Temperature Transmitter Model IPAQ R530X, with a non-metallic enclosure, is a loop powered device that converts the measurement signals of temperature sensors (RTD or thermocouple) or resistance or mV signals into a 4 – 20 mA output signals with HART communication.

The transmitter is provided with a USB port and NFC technology for service and configuration.

#### Ambient temperature range:

$P$	Temperature class	Ambient temperature range
900 mW	T6	-40°C to +55°C
	T5	-40°C to +70°C
	T4	-40°C to +85°C
700 mW	T6	-40°C to +60°C
	T5	-40°C to +75°C
	T4	-40°C to +85°C

#### Electrical data:

Supply and output circuit (terminals +21 and -22):

In type of protection intrinsic safety Ex ia IIC, only for connection to a certified intrinsically safe circuit; with following maximum values:

$U_i = 30 \text{ V}$ ;  $I_i = 100 \text{ mA}$ ;  $P_i = 0,9 \text{ W}$ ;  $C_i = 23,1 \text{ nF}$ ;  $L_i = 20 \text{ }\mu\text{H}$ .

Sensor circuits (terminals 1 ... 4):

In type of protection intrinsic safety Ex ia IIC, with following maximum values:

$U_o = 6,5 \text{ V}$ ;  $I_o = 11,7 \text{ mA}$ ;  $P_o = 19,1 \text{ mW}$ ;  $C_o = 24 \text{ }\mu\text{F}$ ;  $L_o = 400 \text{ mH}$ .

The sensor circuits are infallible galvanically isolated from the power supply and output circuit and withstand a test voltage of 500 VAC for 1 minute.

Communication port (mini USB connector):

Only for connection to the associated ICON-X or ICON Interface.

The USB circuit is protected in accordance with the requirements of type of protection intrinsic safety Ex ia IIC, and has following maximum values (for information only):

$U_i = 10 \text{ V}$ ,  $I_i = 100 \text{ mA}$ ,  $P_i = 0,25 \text{ W}$  and

$U_o = 30 \text{ V}$ ,  $I_o = 18 \text{ mA}$ ,  $P_o = 135 \text{ mW}$ ,  $C_o = 66 \text{ nF}$ ,  $L_o = 40 \text{ mH}$ .

**Variation 1** - This variation introduced the following changes:

- Change of electronics and printed circuit board layout.
- Update of the ambient temperature range related to the supply input power parameter
- Update of the marking plates, installation manual and control drawing
- Update of a standard from EN 60079-0: 2012 + A11: 2013 to EN IEC 60079-0: 2018

**Variation 2** - This variation introduced the following changes:

- To permit the update of the address on the side label to list the postal address in place of PO box address.

Project Number 80213753

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



**SCHEDULE**

**EU-TYPE EXAMINATION CERTIFICATE**

**KIWA 17ATEX0055X  
Issue 3**

- ii. To permit minor change to the construction of the transformer.
- iii. To permit minor technical / administrative changes to drawings not affecting previous assessments.

**14 DESCRIPTIVE DOCUMENTS**

**14.1 Drawings**

Refer to Certificate Annexe.

**14.2 Associated Reports and Certificate History**

Issue	Date	Report number	Comment
1	15 March 2018	171101122-1	The release of the prime certificate.
2	25 May 2021	R80072673A	The introduction of Variation 1.
3	27 August 2024	R80213754A	The introduction of Variation 2.

**15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)**

15.1 The communication port (USB connection) may only be connected to the associated ICON Interface if the temperature transmitter is outside of the hazardous area.

- If certified ICON-X interface is used, a connected sensor may be located in the hazardous area.
- If non-Ex ICON interface is used, a connected sensor shall not be located in the hazardous area.

15.2 For the applicable ambient temperature range, refer to the Product Description.

15.3 The transmitter shall be mounted in to a suitable enclosure that provides a degree of protection of at least IP20.

**16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)**

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

**17 CONDITIONS OF MANUFACTURE**

17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Group Netherlands B.V. certificates.

17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.

# Certificate Annexe



Certificate Number: KIWA 17ATEX0055X  
Equipment: Temperature Transmitter, Model IPAQ R530X  
Applicant: INOR Process AB

---

Issue 1: Refer to the report stated in section 14.2

## Issue 2

Drawing	Sheets	Rev.	Date (Stamp)	Title
APPR DESC 821205	1 to 16	2	14 Apr 21	Description of IPAQ R530X / OPTITEMP TT 53 R Ex
APPR BOM 821205-2	1 to 15	2	14 Apr 21	List of components IPAQ R530X / OPTITEMP TT 53 R Ex
APPR BSD 821205-01	1 of 1	2	14 Apr 21	Basic Safety Diagram, IPAQ R530X / TT 53 R Ex
APPR MRPRT 821204-03	1 to 5	-	14 Apr 21	Temperature tests on transmitters
4006524701	1 to 65	3	14 Apr 21	IPAQ C530/R530/C530X/R530X-en Manual
MNB SC-1506	1 of 1	2	14 Apr 21	Model Number Breakdown SC-1506
73R530X000	1 of 3	9	14 Apr 21	Schematic diagram IPAQ R530X / OPTITEMP TT 53 R Ex
Spec 4006051507	1 to 13	1	14 Apr 21	PCB specification and layout R530C / TT 53 R Ex
4006360701	1 of 1	2	14 Apr 21	IPAQ R530X Installation and Control drawing
4007456202	1 of 1	1	14 Apr 21	IPAQ R530X Label 1, 54,5x34,0 ATEX + IECEx

## Issue 3

Drawing	Sheets	Rev.	Date (Stamp)	Title
APPR DL 821205_2	1 of 1	-	19 Jul 24	IPAQ R530X, list of schedule and related drawings.

Project Number 80213753

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands